

Environmental Health and Safety

Open Flame Ceremony Procedure



Open Flame Ceremony Procedure

Table of Contents

- I. General
- II. Restrictions
- III. Permit Request

Request Ceremony Event

Approval or Denial Process

- IV. Ceremony Procedure
- V. Candles, Incense, and Open Flame Safety Requirements
 Disposal of Candles, Incense, and Open Flame Devices
- VI. Emergency Information
- VII. Recordkeeping

<u>Appendix</u>

Appendix A – Open Flame Ceremony Permit



Open Flame Ceremony Procedure

I. GENERAL

The University recognizes that students, faculty, and staff engage in a variety of ceremonies. This procedure is to provide guidance to the University community engaging in these types of ceremonies.

Generally, the use of open flames (including those found in candles), cigarettes, hookah, and incense are not allowed in university-owned residence halls, apartments, and houses. However, candles, incense, and open-flame devices may be used subject to certain restrictions (see Section II).

II. RESTRICTIONS

Upon prior written approval by Environmental Health and Safety (EHS), candles, incense, and/or open flame devices may be used during religious, cultural, or honorary events and ceremonies. Candles, incense, or open flames may be used in designated spaces (i.e. lounges) in university-owned residence halls, apartments, and houses. Designated space(s) will be identified on the approved permit. Plants used for a ceremony may include sage, sweetgrass, and cedar.

III. PERMIT REQUEST

Request Ceremony Event

To request an open flame ceremony type event, an Open Flame Ceremony Permit (Appendix A) must be completed and submitted to the EHS office a minimum of ten (10) days before the ceremony date.

Approval and Denial Process

EHS will review the permit to determine if the request will be approved or denied. The reviewing process will include, but is not limited to:

- Location of the ceremony;
- Type of candles, incense, or open flame device being used;
- Number of participants;
- Fire Alarm (smoke detection) System in the room and area;
- Ventilation system in the room and area;
- Exits and room setup;
- Health and/or medical concerns; and
- Name of contact at the relevant department (e.g. Housing) regarding the permit request.

Approval can be given by the Environmental Health and Safety Department or AVP of Facilities Management.

IV. CEREMONY PROCEDURE

Once an approved permit is obtained, the ceremony may proceed only on the date and time stated on the permit. A copy of the approved permit must be present, at the designated area, during the ceremony. The following requirements shall be followed during the ceremony:

- UNC Police Department shall be notified 30 minutes before the beginning of the ceremony.
- Section V, below (Candles, Incense, and Open Flame Safety Requirements), must be followed during the ceremony event.
- During the ceremony, an individual (who is not a participant in the event) shall be
 assigned to keep a fire watch and shall have a fire extinguisher present. The fire watch
 shall be present when the event begins and until all candles, incense, or open flames
 are extinguished and have stopped burning.
- Flames shall be immediately extinguished properly at the conclusion of the ceremony.
- Once the ceremony is complete and all items have stopped burning, the University Police Department shall be notified that the ceremony is finished.

Students, faculty, and staff may be held financially accountable for any damage to person or property that results from a violation of this procedure and disciplinary action may be taken against any person involved in such violation. Individuals who provide or contribute materials to burn or who ignite or attempt to ignite flammable materials, in addition to what is listed on the permit, will be considered in violation of this procedure and any such actions may violate state and city regulations.

V. CANDLE, INCENSE, AND OPEN FLAME SAFETY REQUIREMENTS

If the permit is approved, the following requirements are required for candles, incense, or openflame devices:

- No person under the age of 16 will be allowed to hold or light a candle, incense, or open flame (unless approved by Environmental Health and Safety).
- Candles, incense, or open flame devices must be under constant supervision and shall not be unattended while burning.
- Candles, incense, or open flame devices shall be lit only during the ceremony.
- Candles, incense, or open flame devices must not be placed on windowsills or other areas that are unstable or where they could come into contact with curtains or other hanging objects.
- Candles, incense, or open flame devices will not be permitted in areas where occupants are standing in aisles or exits.
- Readily combustible materials, including draperies, curtains, and papers, must be a minimum of three (3) feet away from any candle, incense, or open flame.
- Lighted candles must be placed in a non-combustible candle holder or container.
- No lit candle may be held without a holder or collar.
- Each candleholder shall have an upturned collar, 4 inches in diameter, to keep any hot wax from dripping onto a person's hand, clothing, or the floor. The candle holder shall be made of noncombustible materials (not cardboard).
- Hand-held, lighted candles shall not be passed from one person to another.
- Candlesticks may not be used that exceed four (4) inches in height.
- Candles must be burned upright.
- Approved use of stick incense must be burned in such a manner that hot ashes do not contact any combustible material or cause damage to any surface upon which they fall.

Candles, incense, or open flame devices must not be used in close proximity to active
heat and smoke detectors or sprinkler heads in such a way that the heat or smoke might
activate the devices.

Disposal of Candles, Incense, or Open Flame Devices

- Position the candlestick or open flame device in a non-combustible pan containing onehalf inch of water. The pan must be large enough to catch the candle(s) if they fall.
- During the cooling process, place the pan on a table or desk completely clear of other materials and away from shelves and open windows.
- Place sage, cedar, and sweetgrass in a non-combustible container with an airtight lid.
- Once all candles, incense, and open flame devices are completely cooled, they shall be removed from the premises immediately after the ceremony.

VI. EMERGENCY INFORMATION

In the case of an emergency, the University Police Department must be contacted immediately at 911 or (970) 351-2245.

In case of an uncontrolled fire, use a fire extinguisher if safe to do so. Otherwise, evacuate the building and contact the University Police Department.

VII. RECORDKEEPING

Completed Open Flame Ceremony Permit (Appendix A) shall be kept on file, in EHS Department for a minimum of one (1) year after the event completion date.



Open Flame Ceremony Permit

Requestor Name (Please Print):	Requestor Ph	Requestor Phone Number:			Today's Date:		
Requestor Affiliation to Campus: ☐ Student ☐ Faculty	Requestor Er	Requestor Email Address:			Campus Affiliated Organization: ☐ Yes ☐ No		
Event Location (Be specific; Building, Ro	oom Number):				Type of Event:		
Date(s) of Event:	Start Time of	Start Time of Event:		End Time of E	vent:		
,		AM	PM	AM PM		PM	
Minimum Expected Attendance Max	timum Expected Attendance:	Approximate ag ☐ < 17	proximate age of attendees: < 17 □ 17 or greater				
Type of Permit Requested: ☐ Candle Use ☐ Incense – Type: ☐ Other							
Brief Description of Ceremony:							
I understand that if the permit is approved, I must meet with Housing and Residential Education (or the appropriate department) to develop a plan for the ceremony. I agree to abide by the Open Flame Ceremony Procedure and any additional requirements listed below (after approval).							
Requestor Signature		Date					
The permit must be complete		Environmenta		and Safety o	ffice a minimum of t	ten (10)	
Send the Completed Form to UNC Environmental Health & Safety Department at Campus Box 57 or 501 20 th Street, Greeley CO 80639							
Send the Co	mpleted Form to UNC E Campus Box 57 or 501	nvironmental H I 20 th Street, Gro	ealth & S eeley CO	afety Departm 80639	nent at		
	mpleted Form to UNC E Campus Box 57 or 50 Vironmental Hea	I 20 th Street, Gro	eeley CO	80639			
	Campus Box 57 or 50° vironmental Hea	I 20 th Street, Gro	eeley CO	80639			
En	Campus Box 57 or 50° vironmental Hea	I 20 th Street, Groalth and Sa	eley CO afety L	80639 ISE ONL ke or Heat D			
En Fire Protection System Impaired (Check □ Fire Alarm System □ Water Supply	Campus Box 57 or 50° Vironmental Hea all that apply): □ Duct Detection Sy	I 20 th Street, Groalth and Sa	eley CO afety U	80639 ISE ONL ke or Heat D	Υ		
Fire Protection System Impaired (Check ☐ Fire Alarm System ☐ Water Supply Ceremony Information:	Campus Box 57 or 50° Vironmental Hea all that apply): □ Duct Detection Sy	I 20 th Street, Gro alth and Sa stem er System	eley CO afety U	80639 VSE ONL No. 1995 ke or Heat Der	Υ		
Fire Protection System Impaired (Check ☐ Fire Alarm System ☐ Water Supply Ceremony Information:	Campus Box 57 or 50° Vironmental Hea all that apply): □ Duct Detection Sy □ Automatic Sprinkle	I 20 th Street, Gro alth and Sa stem er System	□ Smo	80639 VSE ONL No. 1995 ke or Heat Der	Υ		
Fire Protection System Impaired (Check	Campus Box 57 or 50° Vironmental Hea all that apply): □ Duct Detection Sy □ Automatic Sprinkle	I 20 th Street, Gro alth and Sa stem er System	□ Smo	80639 VSE ONL No. 1995 ke or Heat Der	Υ		
Fire Protection System Impaired (Check	Campus Box 57 or 50° Vironmental Hea all that apply): □ Duct Detection Sy □ Automatic Sprinkle	alth and Sastem er System	□ Smo	80639 VSE ONL No. 1995 ke or Heat Der	Υ		
Fire Protection System Impaired (Check Fire Alarm System Water Supply Ceremony Information: Comments:	Campus Box 57 or 50° Vironmental Hea all that apply): Duct Detection Sy Automatic Sprinkle	alth and Sastem er System	□ Smo	80639 VSE ONL No. 1995 ke or Heat Der	Y retection System		
Fire Protection System Impaired (Check Fire Alarm System Water Supply Ceremony Information: Comments: EHS Review (Print Name):	Campus Box 57 or 50° Vironmental Hea all that apply): Duct Detection Sy Automatic Sprinkle	alth and Sastem er System	□ Smo	80639 VSE ONL No. 1995 ke or Heat Der	Y retection System		
Fire Protection System Impaired (Check Fire Alarm System Water Supply Ceremony Information: Comments: EHS Review (Print Name):	Campus Box 57 or 50° Vironmental Hea all that apply): Duct Detection Sy Automatic Sprinkle	alth and Sastem er System	□ Smo	80639 VSE ONL No. 1995 ke or Heat Der	Y retection System		